

PUBLIC NOTICE

PAID PUBLIC NOTICE

2014 Annual Drinking Water Quality Report For Berlin Township June 16, 2015

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality of water and the services we provide to you every day. Our constant goal is to provide with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Your source of water comes from the Detroit River, situated within the Lake St. Clair, Clinton River, Detroit River, Rouge River, Ecorse River, in the U.S. and parts of the Thames River, Little River, Turkey Creek and Sydenham watersheds in Canada. The Michigan Department of Natural Resources and Environment in partnership with the U.S. Geological Survey, the Detroit Water and Sewerage Department, and the Michigan Public Health Institute performed a source water assessment to determine the susceptibility of potential contamination. The susceptibility rating is on a six-tiered scale from "very low" to "high" based primarily on geologic sensitivity, water chemistry, and contaminant sources. The susceptibility of our Detroit River source water intakes were determined to be highly susceptible to potential contamination. However, all four Detroit water treatment plants that use source water from the Detroit River have historically provided satisfactory treatment of this source water to meet drinking water standards.

DWSD has initiated source-water protection activities that include chemical containment, spill response, and a mercury reduction program. DWSD participates in a National Pollutant Discharge Elimination System permit discharge program and has an emergency response management plan. If you would like to know more about this report please contact your local water department (734) 586-8680 ext. 6.

I'm pleased to report that our drinking water is safe and meets or exceeds federal and state requirements. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Detroit Water and Sewer Department routinely monitors for contaminants in Berlin Charter Township's drinking water according to federal and state laws. The table provided shows the results of our monitoring for the period of January 1st, to December 31st, 2014. The State allows us to monitor for certain contaminants less than once per year because the concentration of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

Some people may be more vulnerable to contaminants in drinking water than is the general population. Immuno-compromised persons such as a person with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek

PUBLIC NOTICE

advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Berlin Charter Township is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be in source water:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources, such as agricultural, storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

In the table provided you would find many of these terms and abbreviations unfamiliar. To help you better understand these terms we provided definitions:

PUBLIC NOTICE

Key to Detected Contaminants Tables

Symbol, Abbreviation for Definition/Explanation
MCLG: Maximum Contaminant Level Goal

The level of contaminant in drinking water below which there is no known or expected risk to health.

MCL: Maximum Contaminant Level
The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MRDLG: Maximum Residual Disinfectant Level Goal

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MRDL: Maximum Residual Disinfectant Level

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

ppb: Parts per billion (one in one billion)
The ppb is equivalent to micrograms per liter. A microgram = 1/1000 milligram.

ppm: Parts per million (one in one million)
The ppm is equivalent to milligrams per liter. A milligram = 1/1000 gram.

NTU: Nephelometric Turbidity Units
Measures the cloudiness of water.

ND: Not Detected

TT: Treatment Technique
A required process intended to reduce the level of a contaminant in drinking water.

AL: Action Level
The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.

HAA5: Haloacetic acids
HAA5 is the total of bromoacetic, chloroacetic, dibromoacetic, dichloroacetic, and trichloroacetic acids. Compliance is based on the total.

TTHM: Total Trihalomethanes
Total Trihalomethanes is the sum of chloroform, bromodichloromethane, dibromochloromethane, and bromoform. Compliance is based on the total.

n/a: Not applicable

>: Greater than
Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, diarrhea, cramps, and associated headaches.

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for understanding.

If you have any questions about this report or concerning your water utility, please contact Jason Dobson, Berlin Charter Township Wastewater Superintendent 734-586-8680 ext. 6. We want our valued customers to be informed about their water utility. Copies of this report are available at Berlin Charter Township, 8000 Swan View Drive, Newport, MI 48166. Copies of this report will not be mailed.
JUNE 16, 2015

Southwest Water Treatment Plant 2014 Regulated Detected Contaminants Tables

Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Highest Level Detected	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Inorganic Chemicals – Monitoring at Plant Finished Water Tap								
Fluoride	5/13/2014	ppm	4	4	0.56	n/a	no	Erosion of natural deposits; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	5/13/2014	ppm	10	10	0.29	n/a	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Disinfection By-Products – Monitoring in Distribution System Stage 2 Disinfection By-Products								
Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Highest LRAA	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Total Trihalomethanes (TTHM)	8/20/2014	ppb	n/a	80	37.6	0.5-80	no	By-product of drinking water chlorination.
Haloacetic Acids (HAA5)	8/20/2014	ppb	n/a	60	11.0	0.1-60	no	By-product of drinking water disinfection.
Disinfection – Monitoring in Distribution System								
Regulated Contaminant	Test Date	Unit	Health Goal MRDLG	Allowed Level MRDL	Highest RAA	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Total Chlorine Residual	2014	ppm	4	4	0.64	0.52-0.73	no	Water additive used to control microbes.

2014 Turbidity – Monitored every 4 hours at Plant Finished Water Tap				
Highest Single Measurement Cannot exceed 1 NTU	Lowest Monthly % of Samples Meeting Turbidity Limit of 0.3 NTU (minimum 95%)	Violation yes/no	Major Sources in Drinking Water	
0.14 NTU	100%	no	Soil Runoff	
Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.				

2014 Microbiological Contaminants – Monthly Monitoring in Distribution System						
Regulated Contaminant	MCLG	MCL	Highest Number Detected	Violation yes/no	Major Sources in Drinking Water	
Total Coliform Bacteria	0	Presence of Coliform bacteria > 5% of monthly samples	0	no	Naturally present in the environment.	
E. coli Bacteria	0	A routine sample and a repeat sample are total coliform positive, and one is also fecal or E.coli positive.	0	no	Human waste and animal fecal waste.	

2014 Lead and Copper Monitoring at Customers' Tap								
Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Action Level AL	90 th Percentile Value*	Number of Samples Over AL	Violation yes/no	Major Sources in Drinking Water
Lead	2014	ppb	0	15	0	0	no	Corrosion of household plumbing system; Erosion of natural deposits.
Copper	2014	ppm	1.3	1.3	0.031	0	no	Corrosion of household plumbing system; Erosion of natural deposits; Leaching from wood preservatives.
*The 90th percentile value means 90 percent of the homes tested have lead and copper levels below the given 90th percentile value. If the 90th percentile value is above the AL additional requirements must be met.								

Regulated Contaminant	Treatment Technique	Typical Source of Contaminant
Total Organic Carbon (ppm)	The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC was measured each quarter and because the level was low, there is no requirement for TOC removal.	Erosion of natural deposits

Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Level Detected	Violation yes/no	Major Sources in Drinking Water
Combined Radium Radium 226 and 228	5/13/2014	pCi/L	0	5	0.65 +/- 0.54	no	Erosion of natural deposits

2014 Special Monitoring			
Contaminant	MCLG	MCL	Level Detected
Sodium (ppm)	n/a	n/a	5.41
			Source of Contamination
			Erosion of natural deposits

Collection and sampling result information in the table provided by Detroit Water and Sewerage Department (DWSD) Water Quality Division, Mt. Senegen.